

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Scott	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 29	Township number T 17 S R 31 E/W	Range number
2. Distance and direction from nearest town or city: 6E, 4N, 1 1/2 E, 1 1/2 N			3. Owner of well: Larry Huck		
Street address of well location if in city: of Scott City, KS			R.R. or street: 1018 Russell		
			City, state, zip code: Scott City, KS 67871		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 185 ft. 6-16-76	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 185 ft. depth Wall Thickness _____ inches or Dia. _____ in. to _____ ft. depth gage No. 188	
5. Type and color of material		From	To	10. Screen: Manufacturer's name Free Flow	
Clay		0	35	Type Prime Steel Dia. 16 in.	
Gyp		35	50	lot/gauze 125 Length 40 ft.	
Rock H		50	52	Set between 145 ft. and 185 ft.	
Clay		52	60	ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 3/4 - 1/4	
Sd coarse		60	115	11. Static water level: _____ mo./day/yr. 123 ft. below land surface Date 6-16-76	
Fine sd clay		115	135	12. Pumping level below land surfaces: 146 ft. after 4 hrs. pumping 260 g.p.m. 149 ft. after 4 hrs. pumping 275 g.p.m.	
Sd coarse		135	140	Estimated maximum yield 275 g.p.m.	
Fine sd clay		140	175	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sd coarse		175	179	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
Clay yellow		179	180	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Shale		180		16. Nearest source of possible contamination: Feed Lot ft. 1320 Direction E Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 7-21-76 Authorized representative 7-21-76	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

17 31 29 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5