

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Scott</b>	Fraction <b>SW 1/4 SW 1/4 SE 1/4</b>	Section number <b>9</b>	Township number <b>T 17 S R 32 E 40</b>
2. Distance and direction from nearest town or city: <b>5N, 2E, 2N, 1/2E</b> Street address of well location if in city: <b>of Scott City, KS</b>			3. Owner of well: <b>Al Janssen</b> R.R. or street: <b>701 College</b> City, state, zip code: <b>Scott City, KS 67871</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>2-28-75</b> Well depth <b>192</b> ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay		0	30	9. Casing: Material <b>Steel</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>10</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>31.67</b> lbs./ft. Dia. <b>16</b> in. to <b>192</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>188</b>	
Gyp		30	45	10. Screen: Manufacturer's name <b>Johnson &amp; Calv. &amp; Prime</b> Free Flow Type <b>Steel</b> Dia. <b>16</b> in. Slot gauge <b>100 &amp; 125</b> Length <b>40</b> ft. Set between <b>152</b> ft. and <b>192</b> ft. ft. and <input type="checkbox"/> ft. Gravel pack? <b>yes</b> Size range of material <b>3/4 - 1/2</b>	
Clay		45	56	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>117</b> ft. below land surface Date <b>12-11-74</b>	
Fine sd clay		56	67	12. Pumping level below land surfaces: <b>420</b> <b>156</b> ft. after <b>4</b> hrs. pumping <b>17</b> g.p.m. <b>168</b> ft. after <b>4</b> hrs. pumping <b>600</b> g.p.m. Estimated maximum yield <b>600</b> g.p.m.	
Sd rock H		67	74	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
Gyp T		74	80	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Fine sd clay		80	86	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
Sd rock		86	92	16. Nearest source of possible contamination: <b>Feed</b> ft. <b>2640</b> Direction <b>N</b> Type <b>Lot</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Fine sd clay T		92	117	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Layne &amp; Bowler</b> Model number <b>180</b> HP <b>600</b> Volts <b>600</b> Length of drop pipe <b>180</b> ft. capacity <b>600</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay		117	134	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Weishaar Drilling</b> <b>232</b> Business name <b>Scott City, KS 67871</b> License No. Address <b>Scott City, KS 67871</b> Signed <b>[Signature]</b> Authorized representative <b>7-19-76</b>	
Fine sd clay		134	176		
Sd coarse		176	191		
Yellow		191	195		
Shale		195			
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWL-5