


1 LOCATION OF WATER WELL		Fraction	Section Number		Township Number	Range Number	
County: Scott		SW 1/4 NW 1/4 NW 1/4	29		T 17 S	R 32 EW	
Distance and direction from nearest town or city? 5 Miles North 1 East of Scott City, Kansas			Street address of well if located within city?				
2 WATER WELL OWNER: Lucille M. Spreier Spreier							
RR#, St. Address, Box # :			Board of Agriculture, Division of Water Resources				
City, State, ZIP Code: Jetmore, Kansas 67854			Application Number: 26196				
3 DEPTH OF COMPLETED WELL: 305 ft. Bore Hole Diameter: 26 in. to 305 ft. and in. to ft.							
Well Water to be used as:							
1 Domestic 3 Feedlot 6 Oil field water supply 8 Air conditioning 11 Injection well							
2 Irrigation 4 Industrial 7 Lawn and garden only 9 Dewatering 12 Other (Specify below)							
10 Observation well							
Well's static water level: 149 ft. below land surface measured on 12 month 3 day 1980 year							
Pump Test Data: Well water was 166 ft. after 4 hours pumping 880 gpm							
Est. Yield 1450 gpm: Well water was 175 ft. after 8 hours pumping 1450 gpm							
4 TYPE OF BLANK CASING USED:							
1 Steel 3 RMP (SR) 6 Asbestos-Cement 8 Concrete tile Casing Joints: Welded Clamped							
2 PVC 4 ABS 7 Fiberglass Threaded							
Blank casing dia: 16 in. to 175 ft. Dia: 16 in. to 265 ft. Dia: in. to ft.							
Casing height above land surface: 12 in., weight 31.67 lbs./ft. Wall thickness or gauge No. 188							
TYPE OF SCREEN OR PERFORATION MATERIAL:							
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)							
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)							
Screen or Perforation Openings Are:							
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)							
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) Extruded Bridge type							
Screen-Perforation Dia: 16 in. to 225 ft. Dia: 16 in. to 305 ft. Dia: in. to ft.							
Screen-Perforated Intervals: From: 175 ft. to 225 ft. From: ft. to ft.							
From: 265 ft. to 305 ft. From: ft. to ft.							
Gravel Pack Intervals: From: 15 ft. to 305 ft. From: ft. to ft.							
From: ft. to ft. From: ft. to ft.							
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From: 0 ft. to 15 ft. From: ft. to ft. From: ft. to ft.							
What is the nearest source of possible contamination:							
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well							
2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well							
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)							
13 Watertight sewer lines							
Direction from well: South How many feet: 2600 ? Water Well Disinfected: Yes No							
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample							
was submitted month day year: Pump Installed? Yes No							
If Yes: Pump Manufacturer's name Western Land Roller Model No. 4-12-BH HP Volts							
Depth of Pump Intake 295 ft. Pumps Capacity rated at 1200 gal./min.							
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was							
completed on 1 month 6 day 1981 year							
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 252							
This Water Well Record was completed on 1 month 20 day 1981 year under the business							
name of Weishaar Drilling & Supply Inc. by (signature) <i>[Signature]</i>							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	33	Clay	33	34	Gyp
		34	40	Clay	40	52	Gyp
		52	58	Clay	58	100	Sandy clay
		100	165	Fine Sand	165	197	Sand & Gravel
		197	200	Sand Rock	200	207	Fine sand
		207	242	Fine sand clay streaks	242	248	Sand rock
		248	252	Fine sand	252	270	Fine sand clay streaks
		270	275	Fine sand	275	281	Clay
		281	291	Fine sand	291	295	Sand
		295	303	Fine sand	303	305	Yellow clay
ELEVATION:							
Depth(s) Groundwater Encountered 1. 149 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)							
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.							

OFFICE USE ONLY

T

17

R

32

EW

SEC

29

SW

NW

SE

SW

NW

SW