

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CDA

1. Location of well:		County Scott	Fraction N/E 1/4 S/E 1/4 S/W 1/4	Section number 30	Township number T 17 S	Range number R 32 E/W
2. Distance and direction from nearest town or city: 4 N., 1/2 E. of Scott City, Kansas Street address of well location if in city:			3. Owner of well: Gerald Wiechman R.R. or street: Box 728 City, state, zip code: Scott City, Kansas 67871			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: feedlot well 200'			
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 5-24-1978 Well depth 293 ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.67 lbs./ft. Dia. 16 in. to 173 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
					10. Screen: Manufacturer's name Free Flow Type steel Dia. 16" Slot/gauze .125 Length 120' Set between 173 ft. and 293 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 3/4 down	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 114 ft. below land surface Date 5/24/78	
					12. Pumping level below land surfaces: 162 ft. after 4 hrs. pumping 1550 g.p.m. 170 ft. after 4 hrs. pumping 1480 g.p.m. Estimated maximum yield 1480 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 10 Inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. 200 Direction W Type Feed lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 10 HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 240 ft. capacity 1480 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling & Sup. 232 Business name License No. Address Scott City, Kansas 67871 Signed [Signature] Date 6/19/78 Authorized representative	
18. Elevation:		19. Remarks: Block 290 114 176				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5