


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Scott</b>	Fraction <b>NE 1/4 NE 1/4 NE 1/4</b>	Section number <b>12</b>	Township number <b>T 17 S R 33 E 34</b>	Range number
2. Distance and direction from nearest town or city: <b>8N of</b> Street address of well location if in city: <b>Scott City, Kansas</b>				3. Owner of well: <b>Harold Ellis</b> R.R. or street: <b>RFD #1</b> City, state, zip code: <b>Scott City, KS 67871</b>		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: 		
5. Type and color of material				From	To	6. Bore hole dia. <b>9</b> in. Completion date <b>7-17-76</b> Well depth <b>195</b> ft.
<b>Clay</b>				<b>0</b>	<b>48</b>	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
<b>Gyp</b>				<b>48</b>	<b>52</b>	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
<b>Clay</b>				<b>52</b>	<b>55</b>	9. Casing: Material <b>Plas.</b> Height: <b>above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Glue Surface <b>12</b> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <b>1.8</b> lbs./ft. Dia. <b>5</b> in. to <b>175</b> ft. depth Wall Thickness: inches or Dia. <b>5</b> in. to <b>175</b> ft. depth gage No. <b>250</b>
<b>Fine sd clay</b>				<b>55</b>	<b>65</b>	10. Screen: Manufacturer's name <b>Jess &amp; Lowell</b> Type <b>RMP</b> Dia. <b>5 in.</b> Slot gauge <b>1/16</b> Length <b>20 ft.</b> Set between <b>175</b> ft. and <b>195</b> ft. ft. and <b>195</b> ft. Gravel pack? <b>yes</b> Size range of material <b>1/8-1/4</b>
<b>Gyp rock H</b>				<b>65</b>	<b>75</b>	11. Static water level: <b>95</b> ft. below land surface Date <b>7-16-76</b> mo./day/yr.
<b>Clay</b>				<b>75</b>	<b>88</b>	12. Pumping level below land surfaces: <b>105</b> ft. after <b>1</b> hrs. pumping <b>10</b> g.p.m. ft. after <b>1</b> hrs. pumping <b>10</b> g.p.m. Estimated maximum yield <b>10</b> g.p.m.
<b>Fine sd clay</b>				<b>88</b>	<b>105</b>	13. Water sample submitted: <b>Yes</b> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <b>7-16-76</b> mo./day/yr.
<b>Fine sd</b>				<b>105</b>	<b>115</b>	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>12</b> inches above grade
<b>Fine sd clay</b>				<b>115</b>	<b>120</b>	15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>15</b> ft.
<b>Sd rock</b>				<b>120</b>	<b>125</b>	16. Nearest source of possible contamination: <b>Feed</b> ft. <b>300</b> Direction <b>W</b> Type <b>Lot</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<b>Fine sd clay</b>				<b>125</b>	<b>150</b>	17. Pump: Manufacturer's name <b>Red Jacket</b> Not installed Model number <b>100M</b> HP <b>1</b> Volts <b>220</b> Length of drop pipe <b>168</b> ft. capacity <b>10</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
<b>Fine sd</b>				<b>150</b>	<b>182</b>	
<b>Fine sd clay</b>				<b>182</b>	<b>187</b>	
<b>Shale</b>				<b>187</b>	<b>195</b>	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Weishaar Drilling</b> <b>232</b> Business name License No. Address <b>Scott City, KS 67871</b> Signature <b>[Signature]</b> Date <b>8-17-76</b> Authorized representative						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5