

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


LAKE SCOTT SW

1733W 22CCA
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

CCA

1 Location of well:	County SCOTT	Township name NE-SW-SW	Fraction 22	Section number 175	Range number 33W																																							
Distance and direction from nearest town or city: 5 N, 3W, 1/4 N			3 Owner of well: Valley Feeders Inc.																																									
Street address of well location if in city: of C of Scott City			Address: AFD 2 Scott City, KS. 67871																																									
Locate with "X" in section below: Sketch map: 			4 Well depth: 135 ft. Date of completion 6-15-75 Well diameter 9 5/8 in.																																									
2 Type and color of material			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																																									
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Feed yard																																									
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:50%;">Type and color of material</th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr><td>soil and some sand</td><td>0</td><td>20</td></tr> <tr><td>soil and clay</td><td>20</td><td>40</td></tr> <tr><td>sand</td><td>40</td><td>50</td></tr> <tr><td>coarse sand and gyp.</td><td>50</td><td>70</td></tr> <tr><td>sandy clay</td><td>70</td><td>96</td></tr> <tr><td>sand with some clay</td><td>96</td><td>116</td></tr> <tr><td>clay with gravel</td><td>116</td><td>124</td></tr> <tr><td>some clay and gravel</td><td>124</td><td>129</td></tr> <tr><td>sandy clay with some gravel</td><td>129</td><td>133</td></tr> <tr><td>yellow</td><td>133</td><td>136</td></tr> <tr><td>blue</td><td>136</td><td></td></tr> <tr><td colspan="3" style="text-align:center;">BROCK 133'</td></tr> </tbody> </table>			Type and color of material	From	To	soil and some sand	0	20	soil and clay	20	40	sand	40	50	coarse sand and gyp.	50	70	sandy clay	70	96	sand with some clay	96	116	clay with gravel	116	124	some clay and gravel	124	129	sandy clay with some gravel	129	133	yellow	133	136	blue	136		BROCK 133'			7 Casing: Material ABS Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Dig. _____ Weight 7 lbs./ft. _____ 5 in. to 115 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth 1250 wall		
			Type and color of material	From	To																																							
			soil and some sand	0	20																																							
			soil and clay	20	40																																							
			sand	40	50																																							
			coarse sand and gyp.	50	70																																							
			sandy clay	70	96																																							
			sand with some clay	96	116																																							
			clay with gravel	116	124																																							
			some clay and gravel	124	129																																							
sandy clay with some gravel	129	133																																										
yellow	133	136																																										
blue	136																																											
BROCK 133'																																												
8 Screen: Manufacturer Jess & Lowell Type ABS Dia. 5" I.D. Slot gauge 110 Length 20' Set between 116 ft. and 136 ft. _____ Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8 down																																												
9 Static water level: 65 ft. below land surface Date 6-1-75																																												
10 Pumping level below land surfaces: 130 ft. after 2 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.																																												
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																																												
12 Well head completion: <input checked="" type="checkbox"/> Pitless unit <input type="checkbox"/> Inches above grade																																												
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 20 ft.																																												
14 Nearest source of possible contamination: Feed Lot ft. 200 Direction East Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																												
15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 26EL15420 1 1/2 Volts 230 Length of drop pipe 128 ft. capacity 30 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																												
16 Remarks: elevation 2960 (TOPD) Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley																																												
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ABC Drilling Co 246 Business name License No. Address: Scott City, KS. 67871 Signed: Dell Nottingham Date 7-6-75 Authorized representative																																												

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5