

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 28	Township number T 17 S R 33 E 40	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
			Wayne Rudolph RFD #3 Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>188</u> ft. <u>7-13-76</u>	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stack <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay		0		55		9. Casing: Material <u>Steel</u> Height: <u>above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.62</u> lbs./ft. Dia. <u>16</u> in. to <u>188</u> ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth Page No. <u>188</u>
Fine sd clay		55		60		10. Screen: Manufacturer's name <u>Free Flow</u> Type <u>Prime Steel</u> Dia. <u>16 in.</u> <u>Not</u> gauze <u>125</u> Length <u>40 ft.</u> Set between <u>148</u> ft. and <u>188</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>3/4 - 1/2</u>
Sd coarse		60		67		11. Static water level: <u>125</u> ft. below land surface Date <u>6-25-76</u> mo./day/yr.
Sd rock H		67		70		12. Pumping level below land surfaces: <u>173</u> ft. after <u>4</u> hrs. pumping <u>720</u> g.p.m. <u>176</u> ft. after <u>4</u> hrs. pumping <u>740</u> g.p.m. Estimated maximum yield <u>740</u> g.p.m.
Gyp		70		83		13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
Fine sd clay		83		87		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade <input checked="" type="checkbox"/> Well grouted? _____ With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Sd rock		87		100		16. Nearest source of possible contamination: ft. <u>5280</u> Direction <u>N</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Fine sd clay		100		122		17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number _____ HP _____ Volts _____ Length of drop pipe <u>180</u> ft. capacity <u>740</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
F Med Sd		122		138		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date <u>7-22-76</u> Authorized Representative
Sd rock		138		140		
Fine sd clay		140		172		
Sd coarse		172		185		
Yellow		185		188		
Shale		188				
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

17 33 28
Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5