

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SE 1/4 NE 1/4 SW 1/4	Section number 29	Township number T 17 S	Range number R 33 W
2. Distance and direction from nearest town or city: 4 Miles North 4 1/2 West 1/2 North of Scott Street address of well location if in city: City, Kansas				3. Owner of well: Hess Bros. R.R. or street: RFD # 3 City, state, zip code: Scott City, Kansas 67871		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>192</u> ft. <u>6/7/79</u>	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>152</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>		
				10. Screen: Manufacturer's name _____ <u>Free Flow</u> Type <u>Prime steel</u> Dia. <u>16"</u> Slot/gauze <u>.125</u> Length <u>40'</u> Set between <u>152</u> ft. and <u>192</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>3/4K 1/2"</u>		
				11. Static water level: _____ mo./day/yr. <u>138</u> ft. below land surface Date <u>5/28/79</u>		
				12. Pumping level below land surfaces: <u>174</u> ft. after <u>4</u> hrs. pumping <u>620</u> g.p.m. <u>178</u> ft. after <u>8</u> hrs. pumping <u>810</u> g.p.m. Estimated maximum yield <u>800</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
				16. Nearest source of possible contamination: ft. <u>1600</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Worthington</u> Model number _____ HP _____ Volts _____ Length of drop pipe <u>180</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling & Sup 232</u> Business name License No. _____ Address <u>Scott City, Kansas 67871</u> Signed <u>[Signature]</u> Date <u>6/7/79</u> Authorized representative
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5