

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County <u>Scott</u>	Fraction <u>SE 1/4 SW 1/4 SW 1/4</u>	Section number <u>15</u>	Township number <u>T 17 S R 34 E</u>	Range number <u>34</u>
2. Distance and direction from nearest town or city: <u>6N, 1/4 E of Modoc, Kansas</u>				3. Owner of well: <u>Decker Bros. % Larry Decker</u> R.R. or street: <u>RFD #3</u> City, state, zip code: <u>Scott City, Kansas 67871</u>		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>125</u> ft. <u>3-13-76</u>	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	4	9. Casing: Material <u>Plas.</u> Height: <u>Above</u> or below Threaded _____ Welded <u>Glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>105</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>		
Rock H		4	20	10. Screen: Manufacturer's name _____ <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5</u> in. <input checked="" type="checkbox"/> Slot gauze <u>1/16</u> Length <u>20</u> ft. Set between <u>105</u> ft. and <u>125</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/8</u>		
Sd coarse		20	32	11. Static water level: _____ mo./day/yr. <u>65</u> ft. below land surface Date <u>3-11-76</u>		
Fine sd clay T		32	50	12. Pumping level below land surfaces: <u>75</u> ft. after <u>1</u> hrs. pumping <u>18</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Sd coarse		50	55	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sd rock		55	59	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ <u>12</u> Inches above grade		
Fine sd clay		59	95	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <u>0</u> ft. to <u>15</u> ft.		
Fine sd Good		95	112	16. Nearest source of possible contamination: _____ ft. _____ Direction <u>SE</u> Type <u>Pen</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
Fine sd clay		112	116	17. Pump: _____ Not installed Manufacturer's name <u>Red Jacket</u> Model number <u>200T1</u> HP <u>2</u> Volts <u>220</u> Length of drop pipe <u>121</u> ft. capacity <u>18</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other		
Med sd		116	122	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signed _____ Date <u>4-21-76</u> Authorized representative		
Yellow		122	135			
Shale		135				
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5