## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number	
1. Location of well:	Wichita	SW 1/4 SW 1/4 NE	1/4	15		т 17 s	R 35	E 🐼
2. Distance and direction from nearest town or city: $6\frac{1}{2}N$ , $2\frac{1}{2}E$ of 3. Owner				ner of well:		Simons Farms Inc.		
Street address of well location if in city: Marienthal, Kansas  R.R. or s City, sto				street: tate, zip code:		Box 113 Marienthal, KS 67863		
						6. Bore hole dia. 9 in. Completion date		
Yull						Well depth 130 ft.		
4. Locate with "X" in section below:						7Cable tool X_RotaryDrivenDugHollow rodJettedBoredReverse rotary  8. Use: X_DomesticPublic supplyIndustryIrrigationAir conditioningStockLownOil field waterOther  9. Casing: Material PlasHeight Above to below ThreadedWelded Glue Surface12in.  RMP_XPVCWeight1.8lbs./ft.  Dia .5in. to 100 ft. depth Wall Thickness: inches or		
5. Type and color of material				From	То	Diain. toft. depth gage No250		
01						Jess & L	owell	
Clay				-	2		Dia <b>Z.15</b> _5	t.
Gyp				2	6	Set between100ft, and130ft.		
Sd coarse				6	12	Gravel pack? <u>Yes</u> Size range of material # 1/8 ft.		
Clay				12	21	11. Static water level: mo./day/yr. 46 ft. below land surface Date 7-30-76		
Sd fine				21	26	12. Pumping level below lan	d surfaces:	
Sd rock				26	32	ft. after hrs. pumping g.p.m g.p.m.		
Sd coarse				32	36	Estimated maximum yieldg.p.m.  13. Water sample submitted:mo./day/yr.		
						Yes X No Date		
Sd rock				36	40	14. Well head completion: X Pitless adapter	12 Inches above s	rade
Fine sd clay				40	69	15. Well grouted? VAS		
Sd fine				69	112	With: X Neat cement Bentonite Concrete Depth: From ft. to ft.		
Sd coarse				112	129	16. Nearest source of possible contamination:		
Clay yellow				129	148	ft. 250 Direction SE Type Septic Well disinfected upon completion? X Yes No		
						17. Pump:	Not installed	
Shale				148	150	Model number 300T1	HP Vol6	20
						Length of drop pipe 126	~^	g.p.m.
						X Submersible	Turbine	
(Use a second sheet if needed)						Jet Centrifugal	Reciprod	ating
18. Elevation:	19. Remarks:					20. Water well contractor's	certification:	
						This well was drilled under m is true to the best of my know		eport
Topography:						Weishaar Dri	lline	232
Hill Slope						Business name Sout C	it Kanas	7871
Upland						Sin March	1 tour	
Valley						Authorized rep	resentative 9-7-7	