

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 17	Township number T 17 S R	Range number 35 E
2. Distance and direction from nearest town or city: 6N, 1/2E of Street address of well location if in city: Marienthal, Kansas				3. Owner of well: Robt. Simon R.R. or street: City, state, zip code: Marienthal, KS 67863		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 in. Completion date _____ Well depth 195 ft. 5-21-76	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	25	9. Casing: Material Plas. Height: Above or below Threading _____ Welded GLUE Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight 1.8 lbs./ft. Dia. 5 in. to 175 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250		
Gyp		25	60	10. Screen: Manufacturer's name _____ Jess & Lowell Type RMP Dia. 5 in. Plot gauze 1/16 Length 20 ft. Set between 175 ft. and 195 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/8		
Sdy clay		60	90	11. Static water level: _____ mo./day/yr. 116 ft. below land surface Date 4-26-76		
Sd coarse		90	97	12. Pumping level below land surfaces: 126 ft. after 1 hrs. pumping 18 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Clay		97	108	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
Sdy clay		108	118	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Sd rock		118	120	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 15 ft.		
Fine sd clay		120	126	16. Nearest source of possible contamination: Feed ft. 5280 Direction NW Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
Clay sdy		126	140	17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 15071 HP 1 1/2 Volts 220 Length of drop pipe 185 ft. capacity 18 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
Fine sd clay		140	150			
Clay sdy		150	161			
Fine sd clay		161	182			
Sd coarse		182	187			
Clay sdy "fine"		187	193			
Yellow		193	195			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address _____ City _____ State _____ Zip _____ Signed _____ Date 6-4-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

17 35 W 17 1/4 SE SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5