## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number		
1. Location of well:	Wichita	NW 1/4 SE 1/4 SW 1/		26		r 17 s	R 35	E. <b>(</b> (4)	
, 2 miles Fast				ner of well: Robert Robbins					
and 4 miles N of Marienthal, Kansas R.R. or Street address of well location if in city: City, sh				tate, zip code: Modoc, Kansas					
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. $28$ in. Completion date $4-6-76$			1-6-76	
N Approx. 1000' W & 1000'					of	Well depth 209 ft.			
the SE corner of the SW				<b>1</b> ∕4, Sec26		7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored 🛣 Reverse rotary			
T179 P35W Wichita Counts					Ks.	8. Use: Domestic Public supply Industry			
# W						X Irrigation Air conditioning Stock Lawn Oil field water Other			
sw  se						9. Casing: Material _STL_ Height: Above or below			
						Threaded WeldedX			
5 I←── 1 Mile ───── I						Dia. 16 in. to 179ft. depth Wall Thickness: inches or			
5. Type and color of	material			From	То	Dia in. to ft. dept  10. Screen: Manufacturer's no		1.9	
Top soil				0	2		3.611		
Top soil				2	23	Type			
Tan clay					23	Set betweenft. o		ft.	
Tan clay and limestone			23	51	Gravel pack? ye.stize ran		4mm		
Limestone				51	69	11. Static water level: mo./day/yr.  148 ft. below land surface Date 2-12-76			
Tan clay with limestone lite coarse gravel				69	80	12. Pumping level below land surfaces: 186 ft. after 1 hrs. pumping 333 g.p.m.			
Tan clay with light limestone streaks				80	115	198 ft. after 1 hrs. pumping 283 g.p.m.			
Tan clay with fine sand streaks				115	137	Estimated maximum yield			
Fine to coarse sand med. grabel				137	157	Yes X No Date  14. Well head completion:			
Tan and yellow clay with fine sand				157	159	Pitless adapter Inches above grade			
Tan and yellow clay				159	178	15. Well grouted? <u>yes.</u> With: Neat cement <u> Bentonite</u> Concrete			
Fine to coarse sand med. gravel				178	209	Depth: From O ft. to 10 ft.  16. Nearest source of possible contamination: Unk			
Yellow clay				209	211	ft Direction Type			
Tellow Clay				207		17. Pump:	X Not installed	س ٍ ا	
Black shale				211	220	Manufacturer's name		<u> </u>	
						Model number	_ HP Vo _ ft. capacity		
						Type: Submersible	Turbin	3	
						Jet	Recipr	ocating	
(Use a second sheet if needed)  18. Elevation: 19. Remarks:				<u>.                                    </u>		Centrifugal 20. Water well contractor's co	Other		
10. Elevation:	17. Normana,					This well was drilled under my			
Тородгарну:					is true to the best of my knowledge and belief.  Lavne - Western Co. 150				
Hill Slope						Business name  License No.  Address  Garden City, Kansas			
X Upland						Signed Paris 5-24-76			
Valley						Authorized repr	esentative Dute		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5