

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 33	Township number T 17 S R 35 E	Range number 35 E
2. Distance and direction from nearest town or city: 1/2 E, 3N, 1/4 NE of			3. Owner of well: Harry Paul			
Street address of well location if in city: Marienthal, KS			R.R. or street: City, state, zip code: Marienthal, KS 67863			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 197 ft. 2-10-76		
		<p><i>X well 1000'</i></p> <p><i>Septic</i></p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	23	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 197 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. .188		
Caliche		23	36	10. Screen: Manufacturer's name Johnson Type Galv. Steel Dia. 16 in. Slot/gauze .100 Length 20 ft. Set between 177 ft. and 197 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/4-1/2		
Sand + gravel		36	49	11. Static water level: _____ mo./day/yr. 137 ft. below land surface Date 1-6-76		
Sand rock		49	53	12. Pumping level below land surfaces: 178 ft. after 4 hrs. pumping 370 g.p.m. 189 ft. after 4 hrs. pumping 430 g.p.m. Estimated maximum yield 430 g.p.m.		
Caliche		53	72	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay		72	77	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
fine sand w/ clay streaks		77	147	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
Clay		147	177	16. Nearest source of possible contamination: ft. 1000 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand + gravel		177	195	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number GR HP 30 Vol 460 Length of drop pipe 185 ft. capacity 430 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
yellow clay		195	208	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Scott City, KS 67871 Signature <i>[Signature]</i> Date 7-20-76 Authorized representative		
shale		208	J/D			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

12
 35W
 33
 NW
 SE
 SW
 Sec 33 NW 35W
 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5