


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

**RUSSELL SPRINGS 3SE**  
WATER WELL RECORD  
KSA 82a-1201-1215

**CEB**

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Wichita</b>	Township name <b>Edwards NW-1/4, SW-1/4</b>	Fraction	Section number <b>6</b>	Town number <b>T 17 S</b>	Range number <b>R 36 W</b>
Distance and direction from nearest town or city: <b>7 north, 1 east, 1/2 north of Leoti, KS</b> Street address of well location if in city:				3 Owner of well: <b>Lloyd Mace</b> <b>15561 Lori Anne Lane</b> Address: <b>San Jose, CA 95100</b>		
Locate with "X" in section below: N  W X E S 1 Mile				Sketch map:		4 Well depth: <b>198</b> ft. Date of completion <b>3-18-75</b> Well diameter <b>26</b> in.
2 Type and color of material				From To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
Type and color of material				From To		7 Casing: Material <b>Steel</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. Weight <b>3687</b> lbs./ft. <b>1</b> <b>16</b> in. to <b>199</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth
						8 Screen: Manufacturer <b>Johnson Division</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauge Length <b>20'</b> Set between <b>170</b> ft. and <b>190</b> ft. Perforations: <b>160-170, 190-198</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/2"</b> down
Type and color of material				From To		9 Static water level: <b>129</b> ft. below land surface Date <b>4-25-75</b>
						10 Pumping level below land surfaces: <b>161</b> ft. after <b>2</b> hrs. pumping <b>556</b> (g.p.m.) <b>181</b> ft. after <b>4</b> hrs. pumping <b>711</b> (g.p.m.) Estimated maximum yield <b>700</b> g.p.m.
Type and color of material				From To		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						12 Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade
Type and color of material				From To		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.
						14 Nearest source of possible contamination: <b>N/A</b> ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Type and color of material				From To		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Peerless - FMC</b> Model number HP <b>50</b> Volts <b>460</b> Length of drop pipe <b>190</b> ft. capacity <b>700</b> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						16 Remarks: elevation <b>3319 (TOPO)</b> Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
Type and color of material				From To		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drlg. Co., Inc. 208</b> Business name License No. <b>67846</b> Address <b>Box 493, Garden City, KS</b> Signed <b>Richard Wilson</b> Date <b>7/28/75</b> Authorized representative

*The Professionals*  
**MINTER-WILSON DRILLING CO.** Complete Installation and Repairing  
 INCORPORATED

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Wichita County Lloyd Mace February 28, 1975

NE 1/4 NW 1/4 sec. 6 T.17 R.36 Static Water Level 140

Location: 7 miles North of Leoti on Highway 25, 1 mile East & 1/2 mile North. Test # 1 Sec. 6

0	4	Top Soil
4	25	Clay
25	53	GYP
53	75	Sandy Clay
75	84	Sand
84	95	Sand with Clay
95	100	Fine Sand Dirty
100	110	Medium to Coarse sand 50% Clay
110	120	Fine to Medium to Coarse Sand
120	130	Fine Sand 10% Clay
130	144	Sand with 60% Clay
144	150	Fine Sand 20% Clay
150	160	Fine Sand 5% Clay
160	178	Medium Sand
178	181	Clay with Sand
181	190	Gravel
190	198	Yellow
198	200	Blue Shale

(Best Gravel)

TD 198 Screen 20'