

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 25	Township number T 17 S R 36 EW	Range number 36 EW
2. Distance and direction from nearest town or city: 4N, 1 1/2W of Street address of well location if in city: Marienthal, KS			3. Owner of well: Robt. Simon R.R. or street: City, state, zip code: Marienthal, KS 67863			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>203</u> ft. <u>4-25-75</u>		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.62</u> lbs./ft. Dia. <u>16</u> in. to <u>203</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>		
Clay		0	40	10. Screen: Manufacturer's name _____ Free Flow Type <u>Prime Steel</u> Dia. <u>16 in.</u> Slot gauge <u>.125</u> Length <u>40 ft.</u> Set between <u>163</u> ft. and <u>203</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>3/4 - 1/2</u>		
Sd coarse		40	46	11. Static water level: _____ mo./day/yr. <u>141</u> ft. below land surface Date <u>2-12-75</u>		
Sdy clay T		46	50	12. Pumping level below land surfaces: <u>171</u> ft. after <u>4</u> hrs. pumping <u>400</u> g.p.m. <u>191</u> ft. after <u>4</u> hrs. pumping <u>500</u> g.p.m. Estimated maximum yield <u>500</u> g.p.m.		
Gyp		50	68	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Fine sd clay		68	80	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
Sd rock		80	82	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
Fine sd clay		82	110	16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Clay		110	119	17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GE</u> HP <u>40</u> Volts <u>460</u> Length of drop pipe <u>195</u> ft. capacity <u>500</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay yellow		200	213	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date <u>7-19-76</u> Authorized representative		
Shale		213	215			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

17 360 25 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5