

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 28	Township number T 17 S R 36 E	Range number 36 E
2. Distance and direction from nearest town or city: 22W, 5N of Street address of well location if in city: Scott City, KS				3. Owner of well: Gerstberger Bros. R.R. or street: City, state, zip code: Leoti, KS 67861		
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: <i>Septic</i> <i>1/2 mi.</i> <i>X well</i>		6. Bore hole dia. 26 in. Completion date _____ Well depth 202 ft. 3-8-76
5. Type and color of material				From	To	7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary
Clay				0	27	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other
Gyp				27	65	9. Casing: Material Steel Height: above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.67 lbs./ft. Dia. 16 in. to 202 ft. depth; Wall Thickness: inches Dia. ___ in. to ___ ft. depth; gage No. 188
Sdy clay T				65	80	10. Screen: Manufacturer's name Johnson Calv. & Price & Free Flow Type Steel Dia. 16 in. Slot gauge 100 & .125 Length 30 ft. Set between 172 ft. and 202 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4 - 1/2
Clay				80	100	11. Static water level: 125 ft. below land surface Date 1-14-76 mo./day/yr.
Sd coarse				100	105	12. Pumping level below land surfaces: 192 ft. after 4 hrs. pumping 900 g.p.m. 194 ft. after 4 hrs. pumping 910 g.p.m. Estimated maximum yield 910 g.p.m.
Fine sd clay				105	169	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No Date _____
Fine sd				169	191	14. Well head completion: ___ Pitless adapter 12 inches above grade
Sd coarse				191	198	15. Well grouted? <input checked="" type="checkbox"/> With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.
Yellow				198	225	16. Nearest source of possible contamination: ft. 2540 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No
Shale				225		17. Pump: Not installed Manufacturer's name Western Land Roller Model number GE HP 60 Volts 460 Length of drop pipe 190 ft. capacity 19 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signature _____ Date 7-20-76 Authorized representative
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley						

17 36 W Sec 28 NW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5