

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

RUSSEL SPRINGS 35W

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ACC

1 Location of well:	County Wichita	Township name Beaver	Fraction SW SW 1/4, NE 1/4	Section number 5	Town number T 17 S	Range number R 37 W
Distance and direction from nearest town or city: south of Leoti, KS Street address of well location if in city:				3 Owner of well: Lloyd Mace 15561 Lori Anne Lane San Jose, CA 95100 Address:		
Locate with "X" in section below: N W X E S 1 Mile				Sketch map:		
2 Type and color of material				From	To	4 Well depth: 200 ft. Date of completion 3-1-75 Well diameter 26 in.
BROCK 189'						5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
						7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 36.87 lb./ft. 1 16 in. to 201 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot/gauge Length 20' Set between 170 ft. and 190 ft. Perforations: 150-170, 190-200 1/2" down Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
						9 Static water level: 119 ft. below land surface Date 4-23-75
						10 Pumping level below land surfaces: 118 ft. after 2 hrs. pumping 690 160 ft. after 4 hrs. pumping 882 (air) g.p.m. Estimated maximum yield 800 g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
						14 Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless - FMC Model number HP 50 Volt 160 Length of drop pipe 190 ft. capacity 800 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation 3374 (TOP)				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co., Inc 208 Business name License No. Address Box 493, Garden City, KS 67846 Signed [Signature] Date 7/2/75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Wichita County Lloyd Mace February 27, 1975

SW $\frac{1}{4}$ SW $\frac{1}{4}$ NE $\frac{1}{4}$ sec. 5 T. 17 R. 37 Yield 130 Test # 4

Location: 9 miles North of Leoti on Highway 25, $\frac{3}{2}$ miles
West on dirt road, $\frac{1}{4}$ Mile South in the Corner.

0	3	Top Soil
3	26	Clay
26	44	GYP
44	54	Sandy GYP
54	75	Sandy Clay
75	78	Medium Sand
78	83	Sandy Clay
83	93	Clay
93	100	Fine Dirty Sand
100	113	Fine Sand with Clay 50%
113	124	Medium Sand 50% Clay
124	135	Fine Sand 30% Clay
135	143	Fine to Medium Sand 10% Clay
143	149	Fine to Medium to Coarse Sand
149	160	Fine Sand 5% Clay
160	166	Clean Fine Sand (Loose to Medium Sand)
166	170	Medium Sand with some clay balls
170	177	Medium with Fine (Loose)
177	183	Fine Sand 30% Clay
183	189	Gravel
189	200	Yellow to Blue

TD 200 Screen 20'