

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

RUSSELL SPRINGS 35W

WATER WELL RECORD
KSA 82a-1201-1215

CAC

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 6	Township number T 17 S	Range number R 37 1/W
2. Distance and direction from nearest town or city: 9 north, 4 east, 1/2 south, 1/2 east of Leoti.			3. Owner of well: Leonard Keifer R.R. or street: City, state, zip code: Leoti, Ks. 67861			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date 7-31-76 Well depth <u>180</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>181</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
				10. Screen: Manufacturer's name Johnson Type Galv. Dia. <u>16"</u> Slot/groove Length <u>20'</u> Set between <u>150</u> ft. and <u>170</u> ft. Perf: 140-150 ft. and 170-180 ft. Gravel pack? yes Size range of material 1/2" down		
				11. Static water level: <input type="checkbox"/> mo./day/yr. <u>111</u> ft. below land surface Date 7-27-76		
				12. Pumping level below land surfaces: <u>163</u> ft. after <u>3</u> hrs. pumping <u>500</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>500</u> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds- US Pump Model number <u>10JLO</u> HP <u>30</u> Volts <input type="checkbox"/> Length of drop pipe <u>170</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Address Box A Garden City, Ks. Signed <i>[Signature]</i> Date 12-20-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		BROOK 173' 3370 (TCPO)				

17 37E
T
R
Sec
6 SW 1/4 35W

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

LEONARD KIMMER
WICHITA COUNTY
6-5-76

RUSSELL SPRINGS 35W

Location: SW 6-17-37 Hwy 25 1 Mile North of Caprock Feeder
5 Miles West $\frac{1}{2}$ South 1000 Ft. East in Field
Static Water Level- 125'-130'

CAC

Test #1

0	2	Top Soil
2	17	Brown Clay
17	42	Brown Rock Hard Pull Down
42	58	Brown Sandy Clay Hard
58	64	Fine To Med. Sand
64	83	Brown Sandy Clay Tight
83	107	Brown Clay
107	125	Fine To Med. Sand and Gravel
125	170	Fine to Mod. Sand
170	173	Med. Sand To Coarse Gravel Mixed With Yellow Rock
173	176	Yellow Clay
176	180	Shale

TD 176
20 Screen