


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 7	Township number T 17 S R 37 E NW	Range number	
2. Distance and direction from nearest town or city: 4W, 6N, 1W, Street address of well location if in city: 1 3/4N of Leoti, KS				3. Owner of well: Elmer Ridder R.R. or street: City, state, zip code: Marienthal, KS 67863			
4. Locate with "X" in section below:		Sketch map: 			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>165</u> ft. <u>9-24-75</u>		
5. Type and color of material		From	To	7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary			
Clay		0	18	8. Use: Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____			
Sd coarse		18	38	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP _____ PVC _____ Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>165</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. <u>188</u>			
Sdy clay		38	75	10. Screen: Manufacturer's name _____ Free Flow Type <u>Prime Steel</u> Dia. <u>16 in.</u> Gauze <u>125</u> Length <u>30 ft.</u> Set between <u>135</u> ft. and <u>165</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>3/4-1/2</u>			
Clay		75	92	11. Static water level: _____ mo./day/yr. <u>110</u> ft. below land surface Date <u>8-23-75</u>			
Fine sd clay		92	135	12. Pumping level below land surfaces: <u>149</u> ft. after <u>4</u> hrs. pumping <u>410</u> g.p.m. <u>155</u> ft. after <u>4</u> hrs. pumping <u>480</u> g.p.m. Estimated maximum yield <u>480</u> g.p.m.			
Fine sd		135	150	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____			
Sd coarse		150	156	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> Inches above grade			
Sd rock		156	157	15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement _____ Bentonite _____ Concrete <input checked="" type="checkbox"/> Depth: From <u>0</u> ft. to <u>15</u> ft.			
Clay yellow		157	165	16. Nearest source of possible contamination: ft. <u>5280</u> Direction <u>N</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____			
Shale		165		17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GE</u> HP <u>30</u> Volts <u>480</u> Length of drop pipe <u>155</u> ft. capacity <u>480</u> g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____			
(Use a second sheet if needed)							
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signature _____ Date <u>7-20-76</u> Authorized representative _____				

17 32 7
Sec 7
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5