

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 7	Township number T 17 S R 37 E/W	Range number 37
2. Distance and direction from nearest town or city: 4W, xxxx 7 3/4N			3. Owner of well: Elmer Ridder			
Street address of well location if in city: 1/2 W of Leoti, KS			R.R. or street: City, state, zip code: Marienthal, KS 67863			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 176 ft. 9-24-75		
		<p style="text-align: center;">N</p> <p style="text-align: center;">NW --- X --- NE</p> <p style="text-align: center;">SW --- SE</p> <p style="text-align: center;">S</p> <p style="text-align: center;">1 Mile</p>		7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
Clay		0	18	9. Casing: Material Steel Height: above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.67 lbs./ft. Dia. 16 in. to 176 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. .188		
Gyp		18	31	10. Screen: Manufacturer's name Free Flow Type Prime Steel Dia. 16 in. Slot/gauge 125 Length 40 ft. Set between 136 ft. and 176 ft. ___ ft. and ___ ft.		
Fine sd clay		31	77	Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4-1		
Clay		77	84	11. Static water level: _____ mo./day/yr. 110 ft. below land surface Date 8-21-75		
Fine sd clay		84	130	12. Pumping level below land surfaces: 140 ft. after 4 hrs. pumping 850 g.p.m. 145 ft. after 4 hrs. pumping 1000 g.p.m. Estimated maximum yield 1000 g.p.m.		
Fine sd		130	160	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date _____		
Sd coarse		160	168	14. Well head completion: ___ Pitless adapter 12 inches above grade		
Sd rock		168	170	15. Well grouted? <input checked="" type="checkbox"/> With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Clay yellow		170	185	16. Nearest source of possible contamination: ft. 7920 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No		
Shale		185		17. Pump: ___ Not installed Manufacturer's name Western Land Roller Model number US HP 60 Volts 480 Length of drop pipe 165 ft. capacity 1000 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signature <i>[Signature]</i> Date 7-22-76 Authorized representative		
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley						

17 320 7 - SCHWINE
T
R
S
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5