

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 29	Township number T 17 S R 37 E W	Range number 37
2. Distance and direction from nearest town or city: 4W, 4 1/2 N of			3. Owner of well: Art Dearden		
Street address of well location if in city: Leoti, Kansas			R.R. or street: City, state, zip code: Leoti, KS 67861		
4. Locate with "X" in section below:			Sketch map:		
			6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>175</u> ft. <u>4-21-77</u>		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Plas.</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>Glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>155</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.250</u>		
5. Type and color of material			10. Screen: Manufacturer's name _____ Jess & Lowell		
			Type <u>RMP</u> Dia. <u>5 in.</u> <input checked="" type="checkbox"/> gauze <u>1/16</u> Length <u>20 ft.</u> Set between <u>155</u> ft. and <u>175</u> ft. _____ ft. and _____ ft.		
			Gravel pack <input checked="" type="checkbox"/> <u>yes</u> Size range of material <u>1/4-1/8</u> ft.		
			11. Static water level: _____ mo./day/yr. <u>115</u> ft. below land surface Date <u>4-14-77</u>		
			12. Pumping level below land surfaces: <u>125</u> ft. after <u>1</u> hrs. pumping <u>13</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>13</u> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
			16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>SE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name <u>Goulds</u> Model number <u>EM</u> HP <u>1 1/2</u> Volts <u>220</u> Length of drop pipe <u>168</u> ft. capacity <u>13</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name _____ License No. _____ Address <u>Leoti, KS 67871</u> Signed <u>[Signature]</u> Date _____ Authorized representative <u>4-28-77</u>		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 17 S R 37 E W 29 N 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5