

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 31	Township number T 17 S R	Range number 37 E W
2. Distance and direction from nearest town or city: 4W, 3N, 1/2W of			3. Owner of well: M. O. Nuss			
Street address of well location if in city: Leoti, KS			City, state, zip code: Great Bend, KS 67530			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 195 ft. 6-19-75		
				7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
Clay		0	22	9. Casing: Material Steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.67 lbs./ft. Dia. 16 in. to 195 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 188		
Gyp		22	31	10. Screen: Manufacturer's name Free Flow Type Prime Steel Dia. 16 in. <input checked="" type="checkbox"/> gauze .125 Length 40 ft. Set between 155 ft. and 195 ft. ___ ft. and ___ ft.		
Rock H		31	35	Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4-4		
Gyp		35	55	11. Static water level: _____ mo./day/yr. 135 ft. below land surface Date 4-23-75		
Clay		55	63	12. Pumping level below land surfaces: 162 ft. after 4 hrs. pumping 630 g.p.m. 165 ft. after 4 hrs. pumping 650 g.p.m. Estimated maximum yield 650 g.p.m.		
Sd coarse		63	69	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date _____		
Sd rock		69	77	14. Well head completion: ___ Pitless adapter 12 Inches above grade		
Clay		77	95	15. Well grouted? <input checked="" type="checkbox"/> With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
Fine sd clay		95	104	16. Nearest source of possible contamination: Feed ft. 7920 Direction SW Type Lot		
Sd coarse		104	116	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No ___		
Fine sd clay		116	147	17. Pump: ___ Not installed Manufacturer's name Western Land Roller Model number GE HP 40 Volts 460 Length of drop pipe 185 ft. capacity 650 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
Sd coarse		147	158	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 7-20-76 Authorized representative		
Clay		158	170			
Fine sd		170	175			
Clay		175	179			
Fine sd clay	(Use a second sheet if needed)	179	185			
18. Elevation:	19. Remarks:	185	192			
	Sd coarse		192			
	Clay yellow		195			
	Shale					
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley						

T 17 37 W E
R 37 W E
S 37 W E
Sec 31
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WW-5