

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 27	Township number T 17 S R 38 E	Range number 38 E
2. Distance and direction from nearest town or city: 4N, 1E of Selkirk, KS				3. Owner of well: Art Gribben R.R. or street: City, state, zip code: Leoti, KS 67861		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 24 in. Completion date _____ Well depth 200 ft. 8-22-75		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	20	9. Casing: Material Steel Height Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 17.5 lbs./ft. Dia. 12 in. to 200 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 134		
Gyp rock H		20	26	10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 12 in. Slot/gauze .179 Length 40 ft. Set between 160 ft. and 200 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/2-1		
Gyp		26	32	11. Static water level: _____ mo./day/yr. 122 ft. below land surface Date 7-29-75		
Clay		32	42	12. Pumping level below land surfaces: 145 ft. after 4 hrs. pumping 190 g.p.m. 160 ft. after 4 hrs. pumping 420 g.p.m. Estimated maximum yield 420 g.p.m.		
Sd coarse		42	62	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sdy clay		62	71	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Sd coarse		71	82	15. Well grouted? <input checked="" type="checkbox"/> Y With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
Sd rock		82	89	16. Nearest source of possible contamination: ft. 2640 Direction E Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse		89	97	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number US HP 30 Volts 460 Length of drop pipe 190 ft. capacity 420 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay		97	120	18. Elevation:		
Fine sd clay		120	137	19. Remarks:		
Sd coarse		137	143	Clay		
Clay		143	153	Sd coarse		
Sd coarse		153	159	Clay yellow		
Fine sd clay		159	168	Shale		
Sd coarse (Use a second sheet if needed)		168	172	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signature _____ Date _____ Authorized representative 7-20-76		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

17
 38
 27
 SWSWSW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5