


SHARON SPRINGS 4SE

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CCA

1. Location of well: well # 2		County Greeley	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 10	Township number T 17 S R 39 E	Range number 39
2. Distance and direction from nearest town or city: 8 mi. north, & 6 1/2 mi. east of Tribune, Kansas			3. Owner of well: Robert Kleyman R.R. or street: City, state, zip code: Tribune, Kansas 67879			
4. Locate with "X" in section below: 			Sketch map:			6. Bore hole dia. 26 in. Completion date _____ Well depth 200 ft. 5-24-77
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top soil & clay			0	15	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay			15	19	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 40 lbs./ft. Dia. 16 in. to 160 ft. depth Wall Thickness: inches or Dia. 160 in. to 200 ft. depth gage No. .219	
Clay & line			19	45	10. Screen: Manufacturer's name _____ W. A. Brown Type Perf. steel Dia. 16" Slot 2" Length 40 ft. Set between 160 ft. and 200 ft. _____ ft. and _____ ft.	
Cemented sand			45	47	11. Static water level: _____ mo./day/yr. 115 ft. below land surface Date 5-13-77	
Clay & line			47	90	12. Pumping level below land surfaces: 194 ft. after 3 hrs. pumping 700 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 700 g.p.m.	
Clay & a little line			90	105	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Clay & sand streaked			105	120	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Sand & clay			120	135	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Clay streaked with lime			135	139	16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type none Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Clay			139	144	17. Pump: _____ Not installed Manufacturer's name Layne Model number 770329 HP _____ Volts _____ Length of drop pipe 195 ft. capacity 700 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Sand			144	150	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & Supply 123 Business name _____ License No. _____ Address Holly, Colo, 81047 Signed W. Smith Date 6-27 Authorized representative	
Clay (yellow)			190	196		
Shale (blue)			196	200		
18. Elevation:		19. Remarks: BROCK 190 Level ground 3530 (TUPD)				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

L7 320 10 NE SW SW
1/4 1/4 1/4