

USE TYPEWRISER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: Well No. 1	County Greeley	X Section SE 1/4 NE 1/4 NW 1/4	Section number 15	Township number T 17	Range number S R 39	(EW)
2. Distance and direction from nearest town or city: 8 mi. N. & 6 E. of Tribune, Kans.		3. Owner of well: Floyd Kleyman		R.R. or street: Tribune, Kansas 67879		
Street address of well location if in city:		City, state, zip code:				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>192</u> ft. <u>5-25-77</u>		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From To		9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>40</u> lbs./ft. Dia <u>16</u> in. to <u>152</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.219</u>		
				10. Screen: Manufacturer's name <u>W. A. Brown</u> Type <u>Perf. steel</u> Dia. <u>16 in.</u> Slot <u>2"</u> Length <u>40 ft.</u> Set between <u>152</u> ft. and <u>192</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/4 to 5/8</u>		
				11. Static water level: _____ mo./day/yr. <u>100</u> ft. below land surface Date <u>5-24-77</u>		
				12. Pumping level below land surfaces: <u>120</u> ft. after <u>7</u> hrs. pumping <u>800</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>800</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12"</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>None</u> <input checked="" type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Layne</u> Model number <u>770321</u> HP _____ Volts _____ Length of drop pipe <u>190</u> ft. capacity <u>800</u> g.p.m. Type: _____ Submersible <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & Supply 123 Business name _____ License No. _____ Address <u>Holly, Colo. 81047</u> Signed <u>[Signature]</u> Date <u>7-1-77</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Level ground				

12 39 (W) 15 SEVENNW Sec 1/4 1/4 1/4