

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

45SW

1. Location of well:	County Greeley	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 29	Township number T 17 S R 39	Range number 39
2. Distance and direction from nearest town or city: 15W, 5 3/4N,			3. Owner of well: Paul Shafer		
Street address of well location if in city: 1/2 W of Leoti, KS			R.R. or street: Tribune, KS 67879		
4. Locate with "X" in section below:			6. Bore hole dia. 26 in. Completion date _____		
Sketch map: 			Well depth 185 ft. 6-12-76		
			7. Cable tool ___ Rotary ___ Driven ___ Dug Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
			9. Casing: Material Steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC Weight 31.67 lbs./ft. Dia. 16 in. to 185 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 188		
5. Type and color of material			10. Screen: Manufacturer's name Johnson		
			Type Galv. Steel Dia. 16 in.		
Clay			Slot gauge 100 Length 30 ft.		
Gyp			Set between 155 ft. and 185 ft.		
Clay			Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4 - 1/2		
Sd coarse			11. Static water level: _____ mo./day/yr. 120 ft. below land surface Date 5-13-76		
Sdy clay T			12. Pumping level below land surfaces: 161 ft. after 4 hrs. pumping 400 g.p.m. 172 ft. after 4 hrs. pumping 530 g.p.m. Estimated maximum yield 530 g.p.m.		
Sd coarse			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay			<input checked="" type="checkbox"/> Well head completion: Pitless adapter 12 inches above grade		
Fine sd clay			<input checked="" type="checkbox"/> Well grouted? _____ With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Sd rock			16. Nearest source of possible contamination: ft. 18480 Direction S Type Septic		
Fine sd clay			Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No		
Clay			17. Pump: _____ Not installed		
Sd coarse			Manufacturer's name Western Land Roller		
Clay yellow			Model number GE HP 30 Volts 460		
			Length of drop pipe 170 ft. capacity 530 g.p.m.		
			Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: _____ Hill <input checked="" type="checkbox"/> Slope ___ Upland ___ Valley		TOPO 3546			
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ license No. _____ Address Booth City, KS 67871 Signed <i>[Signature]</i> Date _____ Authorized representative 7-21-76			

17 39E 29 SWNE NE Sec 1/4 1/4 1/4