

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Greeley	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 9	Township number T 17 S R 40	Range number EAN
2. Distance and direction from nearest town or city: 8 miles north of Tribune Street address of well location if in city:			3. Owner of well: Gerald Mangold R.R. or street: City, state, zip code: Tribune, Kansas 67879		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>4/20/79</u> Well depth <u>210</u> ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material			From	To	9. Casing: Material <u>Plastic</u> Height: Above or below Threaded <input type="checkbox"/> Welded <u>glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC Weight <u>1.8</u> lbs./ft. Dia. <u>1.5</u> in. to <u>1.90</u> ft. depth Wall Thickness: inches or Dia. <u>1.5</u> in. to <u>1.90</u> ft. depth Gauge No. <u>250</u>
					10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>28'</u> Set between <u>1.90</u> ft. and <u>210</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4 x 1/8</u>
					11. Static water level: <u>160</u> ft. below land surface Date <u>4/14/79</u> mo./day/yr.
					12. Pumping level below land surfaces: <u>170</u> ft. after <u>4</u> hrs. pumping <u>18</u> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>50</u> g.p.m.
					13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
					15. Well grouted? ____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.
					16. Nearest source of possible contamination: ft. <u>50</u> Direction <u>North</u> Type <u>Hoglot</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: ____ Not installed Manufacturer's name <u>Red Jacket</u> Model number <u>150N111CC</u> HP <u>1 1/2</u> Volts <u>230</u> Length of drop pipe <u>200</u> ft. capacity <u>18</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar drilling & Supply 232 Business name <u>Scott City Kansas</u> License No. ____ Address <u>Scott City Kansas</u> Signed <u>[Signature]</u> Date <u>4/19</u> Authorized representative
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	TOPO 3638				

17 40 232
 Sec 9 NW 36 38
 1/4 1/4 1/4