

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Grovelley	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 16	Township number T 17 S R 40 W	Range number
2. Distance and direction from nearest town or city: Tribune Street address of well location if in city: 8 N 1/2 E				3. Owner of well: W.J. MINTNER R.R. or street: City, state, zip code: TRIBUNE KANSAS 67879		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 205 ft. 5-29-79		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Galv Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 4 in. to 181 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1237		
				10. Screen: Manufacturer's name _____ Pitless Type LOWYER Dia. 5 Slot/gauze 1/8 Length 24 Set between 181 ft. and 205 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/8		
				11. Static water level: _____ mo./day/yr. 154 ft. below land surface Date 5-28-79		
				12. Pumping level below land surfaces: 190 ft. after 3 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
				16. Nearest source of possible contamination _____ ft. 150 Direction SOUTH Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		SET CASING @ 205'		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stitt Drilling Co Inc 166 Business name _____ License No. _____ Address Hoards Kansas Signed Bill Clifford Date 5-29-79 Authorized representative		

T 17
 R 40
 E W
 Sec 16
 NE 1/4
 NW 1/4