

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County MCPHERSON	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 36	Township number T 17 S	Range number R 5 E
2. Distance and direction from nearest town or city: 2.50 1 east			3. Owner of well: ROBERT LARSON			
Street address of well location if in city: MARQUETTE KANSAS			R.R. or street: RR			
			City, state, zip code: MARQUETTE, KANSAS			
4. Locate with "X" in section below: Sketch map: N 1 Mile W E S 1 Mile			6. Bore hole dia. 3.0 in. Completion date 7-18 Well depth 61 ft. 76			
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>			
5. Type and color of material			9. Casing: Material TRANSITE Weight: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to 61 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3/4"			
			10. Screen: Manufacturer's name AURORA TILE CO. Type TRANSITE Dia. 16" 10 Slot/gauze 1/8 Length 26 Set between 35 ft. and 61 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 18 ft. below land surface Date 7-20 76			
			12. Pumping level below land surfaces: 52 ft. after 2 hrs. pumping 800 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 900 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> gr Pulverized clay With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. 1000 Direction N Type Well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Bros Model number 60E HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 58 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Peteron Irrigation Co, 136A Business name License No. Address Box 150 Leawards, KS Signed William J. Peteron Date 1-4-77 Authorized representative			
19. Remarks:						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

17-50 36 NW SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5