


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Barton	Fraction 1/4 cnw 1/4 ne 1/4	Section number 12	Township number T 18 S R 14W E/W	Range number 14W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 1/2 SW Hoisington, Ks.			3. Owner of well: L. F. Harper R.R. or street: 1904 18 City, state, zip code: Great Bend, Ks. 67530			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 8 in. Completion date 5-9-78 Well depth 120 ft.			
5. Type and color of material			7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
			8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☒ Stock ☐ Lawn ☐ Oil field water ☐ Other			
			9. Casing: Material ☐ Height: Above ground ☒ Threaded ☐ Welded ☐ Surface 12 in. RMP ☐ PVC ☒ Weight 2.8 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. ☐ in. to ☐ ft. depth gage No. sch 40			
			10. Screen: Manufacturer's name Jetstream Type pvc Dia. 5" Slot/gauze 1/32" Length 20' Set between 100 ft. and 120 ft. Gravel pack? ☒ Size range of material 1/8-3/4"			
			11. Static water level: 31 ft. below land surface Date 5-9-78 mo./day/yr.			
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 30 g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. ____ Yes ☒ No Date ____			
			14. Well head completion: 12 inches above grade ____ Pitless adapter			
			15. Well grouted? ☒ With: ☒ Neat cement ☐ Bentonite ☐ Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. 50 Direction S Type stock Well disinfected upon completion? ☒ Yes ☐ No			
			17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
18. Elevation: 1967 Topography: ____ Hill ____ Slope ☒ Upland ____ Valley			19. Remarks: 1967			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name License No. Address R2 Great Bend, Ks. Signed Kelly Price Date 10-1-78 Authorized representative			