


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Rush</b>	Fraction <b>C 1/4 SW 1/4 SW 1/4</b>	Section number <b>13</b>	Township number <b>T 18 S R 17</b>	Range number <b>17</b>
2. Distance and direction from nearest town or city: <b>1/2 n - 1/2 east of Timken</b> Street address of well location if in city:				3. Owner of well: <b>Frank Pechanec</b> R.R. or street: <b>Timken, Ks. 67582</b> City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>29</b> in. Completion date <b>8-15-77</b> Well depth <b>72</b> ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0 3		9. Casing: Material <b>steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <b>16</b> in. to <b>72</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>7</b>		
Black clay		3 9		10. Screen: Manufacturer's name <b>Doerres</b> Type <b>steel</b> Dia. <b>16</b> Slot/groze <b>3/16</b> Length <b>20</b> Set between <b>52</b> ft. and <b>72</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>3/4-3/8</b>		
Light brown clay		9 29		11. Static water level: <b>32</b> ft. below land surface Date <b>7-1-77</b>		
Sand and clay		29 30		12. Pumping level below land surfaces: <b>46</b> ft. after <b>1</b> hrs. pumping <b>600</b> g.p.m. <b>46</b> ft. after <b>1</b> hrs. pumping <b>1000</b> g.p.m. Estimated maximum yield <b>1000</b> g.p.m.		
Blue clay		30 33		13. Water sample submitted: <b>X</b> Yes <input type="checkbox"/> No Date <b>7-1-77</b>		
Sand and gravel dirty		33 42		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Sand and gravel lot of blue clay		42 46		15. Well grouted? <input checked="" type="checkbox"/> <b>X</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
Sand and gravel coarse loose		46 58		16. Nearest source of possible contamination: ft. <b>4 mi</b> Direction <b>SW</b> Type <b>City</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Green clay		58 59		17. Pump: Manufacturer's name <b>W.L.R.</b> Model number <b>2-14cm</b> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <b>60</b> ft. capacity <b>800</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand and gravel coarse loose		59 66		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rosencrantz-Bemis 134</b> Business name <b>Great Bend, Ks. 67530</b> Address <b>S. Kilgore</b> License No. <b>619-79</b> Signed <b>S. Kilgore</b> Authorized representative		
Gray clay		66 67				
Sand and gravel coarse loose		67 72				
Sandy light gray claysome sand rock		72 80				
Fire clay		80				
B.R. @ 72.5 fpm						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>1956</b>				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5