


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County RUSH	Fraction 1/4 1/4 CSE 1/4	Section number 22	Township number T 18 S R 17 NW	Range number
2. Distance and direction from nearest town or city: 1 1/4 mi.			3. Owner of well: Willard SANCRA			
Street address of well location if in city: TIMKEN, KS			City, state, zip code: TIMKEN, KS			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W  E S 1 Mile</div>			Sketch map:		6. Bore hole dia. 30 in. Completion date _____ Well depth 73 ft. 5-23-77	
5. Type and color of material			From To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material Steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 43 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 3/16"	
					10. Screen: Manufacturer's name _____ DERRY Type Steel Dia. 16" Slot/gauze 1/8" Length 30' Set between 43 ft. and 73 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"-3/4"	
					11. Static water level: _____ mo./day/yr. 28 ft. below land surface Date 5-23-77	
(Use a second sheet if needed)					12. Pumping level below land surfaces: 54 ft. after 4 hrs. pumping 860 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 860 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: LIVE ft. 100 Direction E Type Stock Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: _____ Not installed Manufacturer's name LIQUIDS Model number 2-125 HP 40 Volts _____ Length of drop pipe 60 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 186 Kelly's Water Well Serv Business name License No. _____ Address P2 Great Bend, KS Signed Kelly Price Date 7-7-78 Authorized representative	
					18. Elevation:	
					19. Remarks:	
					Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5