

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Rush	Section S 1/4 NE 1/4 SE 1/4	Section number 29	Township number T 18 S R 17 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: William Besperat R.R. or street: City, state, zip code: Timken, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia 6 3/8 in. Completion date 8/7/75 Well depth 183 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
top soil		0	5	<input checked="" type="checkbox"/> Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/2 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 183 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. 1258		
dark clay		5	37	10. Screen: Manufacturer's name Jet Stream Type PVC Dia. 5" Slot/gauze 25' Length 25' Set between 158 ft. and 183 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material: _____		
gray clay		37	63	11. Static water level: _____ mo./day/yr. 120 ft. below land surface Date 8-7-75		
blue shale		63	135	12. Pumping level below land surfaces: 123 ft. after 1 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
coag stone		135	165	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
sand stone		165	176	14. Well head completion: <input type="checkbox"/> Pitless adapter 15 Inches above grade		
soap stone		176	183	<input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 2 ft. to 10 ft.		
Gal ??				16. Nearest source of possible contamination: ft. _____ Direction None Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kent Water Well Drilling Business name _____ License No. _____ Address E Hiway 40 Signed W.B. Ross Date 8/7/75 Authorized representative		
19. Remarks:				Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5