

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Rush	Fraction NE 1/4 SW 1/4 SE 1/4	Section number 19	Township number T 18 R 18 E 0	Range number 18
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Ralph Weltmer R.R. or street: City, state, zip code: Rush Center, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 9/20/75 Well depth 56 ft.		
		<p>House</p> <p>(Above ground) Gas tanks → X Water well</p>		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Topsoil		0	5	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 56 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258		
Brown Soil		5	15	10. Screen: Manufacturer's name Jet Stream Type PVC Dia. 5 Slot gauze _____ Length 10' Set between 45 ft. and 55 ft. Gravel pack? Yes Size range of material 1/4-1/2		
Brown Soil and Sand		15	25	11. Static water level: _____ mo./day/yr. 45 ft. below land surface Date 9/20/75		
Fine — Medium Sand		25	41	12. Pumping level below land surfaces: 46 ft. after 1 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
Medium Sand		41	53	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Blue Shale		53	56	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade <input checked="" type="checkbox"/> Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 12 ft.		
BR 53' pm				16. Nearest source of possible contamination: Gas tanks ft. 400 Direction South Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name Valley Model number 5120A HP 1/2 Volts 240 Length of drop pipe 51 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation:		
				19. Remarks: None		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199A Business name _____ License No. _____ Address E. Hwy 40 Hays Signed R. B. ... Date 9/20/75 Authorized Representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5