

CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction (1/4 1/4 1/4) Section-Township-Range changed:

listed as 31-185-21W

changed to SE NW NW, 31-185-21W

Other changes: Initial statements: _____

Changed to: _____

Comments: On SE. corner of Lawrence St. & Park Ave.

verification method: Written & legal descriptions, map from county appraiser,
phone call to county appraiser, and Bazine 1:24,000 topo. map. initials: ERD date: 6/27/2001

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

bazine

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

Dogme City
Schwartz Address Lot 23 - Block 3

1 Location of well:		County NESS	Township name BAZINE	Fraction	Section number 31	Town number T185	Range number R21W
Distance and direction from nearest town or city:					3 Owner of well: HERMANN KLEWENOE		
Street address of well location if in city:					Address: BAZINE KANSAS		
Locate with "X" in section below:		Sketch map:					
		<p>4 Well depth: 39 ft. Date of completion: 23-JAN-55 Well diameter: 8 in.</p> <p>5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/></p> <p>7 Casing: Material PASTE Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. Diam. Weight: 250 lbs./ft. 5 in. to 30 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ___ ft. depth!</p>					
2	Type and color of material				From	To	8 Screen:
	TAN CLAY				0	16	Manufacturer JESSE I LOWELL
	STRIP OF SAND				16	24	Type STYRENE Dia. 5"
	SANDY TAN CLAY				24	31	Slot/gauze FINE Length 10
	good CLEAN SAND				31	36	Set between 29 ft. and 39 ft.
	SHALE - BLACK				36	40	Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #1
	OR 36' base						9 Static water level: 52 ft. below land surface Date 23-Jan 55
							10 Pumping level below land surfaces: 33 ft. after 3 hrs. pumping 15 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield ___ g.p.m.
							11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___
							12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 17 inches above grade
							13 Well grouted? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From 0 ft. to 11 ft.
	LOCATION						14 Nearest source of possible contamination: CITY ft. 50 Direction NORTH Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
							15 Pump: <input type="checkbox"/> Not installed Manufacturer's name REDA Model number 109001 HP 1/2 Volts 230 Length of drop pipe 34 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(use a second sheet if needed)							
16 Remarks: elevation					17 Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Dean Watrdome Duly 243A</i> Business name License No. Address <i>Highway Kansas</i> Signed <i>Dean Watrdome</i> Date <i>25-Jan-55</i> Authorized representative		