


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ness	Fraction 1/4 NE 1/4 SW 1/4	Section number 31	Township number T 18 S	Range number R 21 W
2. Distance and direction from nearest town or city: 200' S. of Burgess Ave., SE of Methodist Church Street address of well location if in city: in Lots 9 & 10, Blk 25			3. Owner of well: City of Bazine City Building Bazine, Kansas 67516 R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:  Municipal Well No. 3			6. Bore hole dia. 38 in. Completion date 10/15/77 Well depth 54 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top soil			8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown silty clay			9. Casing: Material Steel Height: Above or Below ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 60 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 43.77 lbs./ft. Dia 12 in. to 44 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.330		
Med. to co. sand & gravel - white rock			10. Screen: Manufacturer's name Mustang Well Supply Corp. Type Stainless steel Dia. 12 in. Slot/gauze 0.40 in. Length 10 ft. Set between 44 ft. and 54 ft. Gravel pack? yes Size range of material 1/8x3/16		
Gray clay			11. Static water level: 33.25 ft. below land surface Date 8/31/77 mo./day/yr.		
Med. to co. sand & gravel - white rock			12. Pumping level below land surfaces: 48.3 ft. after 6 hrs. pumping 75 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 80 g.p.m.		
BR 254 1/2 in			13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
			14. Well head completion: 60 inches above grade <input type="checkbox"/> Pitless adapter		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
			16. Nearest source of possible contamination: Sewer Line ft. 125 Direction West Type Line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Layne & Bowler Not installed Manufacturer's name 8URHC HP 7 1/2 Volts 230 Model number 50 ft. capacity 80 g.p.m. Length of drop pipe 80 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name Wichita, Kansas License No. Address Layne & Bowler Date 11/15/77 Signed Layne & Bowler Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5