

CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction (1/4 1/4 1/4) Section-Township-Range changed:

listed as 30-185-23W

changed to NW SE NE, 31-185-23W

Other changes: Initial statements: _____

Changed to: _____

Comments: _____

verification method: written description at bottom of form, city map on internet,
and Ness City 1:24,000 topo. map. initials: DR date: 6/15/2001

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Sent to BWS
1-10-79

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Ness		Fraction 1/4	SEE REMARKS! 1/4 1/4	Section number 30	Township number T 18 S R 23 E W	Range number 23
2. Distance and direction from nearest town or city: In Ness City, KS			3. Owner of well: City of Ness City			
Street address of well location if in city:			R.R. or street: Ness City, KS 67560			
4. Locote with "X" in section below: N (Did not give legal; just described as typed below.)			Sketch map: 		6. Bore hole dia. 24 in. Completion date Well depth 82 ft. 1-3-76	
5. Type and color of material			From		To	
Clay			0		69	
Sand			69		78	
Sandstone			78		79	
Sand			79		81	
SHALE Shale			81		82	
10. Screen: Manufacturer's name Cook			11. Static water level: 51 ft. below land surface Date 1-3-75			
Type Stainless Steel Dia. 12 in.			12. Pumping level below land surfaces: 71 ft. after 8 hrs. pumping 100 g.p.m.			
Gauge 100 Length 10 ft.			Estimated maximum yield 100 g.p.m.			
Set between 72 ft. and 82 ft.			13. Water sample submitted: mo./day/yr.			
Gravel pack? yes Size range of material 2-4			Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date			
14. Well head completion: Pitless adapter 30 inches above grade			15. Well grouted? yes			
16. Nearest source of possible contamination: ft. 150 Direction SE Sewer Line			With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete			
Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Depth: From 0 ft. to 20 ft.			
17. Pump: Not installed			18. Elevation:			
Manufacturer's name Western Land Roller			19. Remarks: Located in Ness City, KS, within the area bounded by School St., Topeka Ave., Buckeye St. & Cherry St.			
Model number US HP 10 Volt 230			Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			
Length of drop pipe 75 ft. capacity 100 g.p.m.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232			
Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			Business name _____ License No. _____ Address Ness City, KS 67871 Signature _____ Date 1-19-76 Authorized representative			

18 230 30
T R Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5