


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County NESS	Fraction NE NE 1/4 1/4 1/4	Section number 28	Township number T 18 S R 24 E/W	Range number
2. Distance and direction from nearest town or city: 3 MILES WEST 1 MILE NORTH OF NESS. CITY Street address of well location if in city:			3. Owner of well: STEVE CRANSTON R.R. or street: City, state, zip code: NESS CITY, KANSAS 67560		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 31 MAY 1977 Well depth 67 ft.
TOPSOIL			0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
BROWN CLAY			2	14	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
FINE SAND			14	18	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 18 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 47 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250
BROWN CLAY			18	34	10. Screen: Manufacturer's name _____ Type RMP Dia. 5" Slot/gauze 4/4 Length 80 Set between 47 ft. and 67 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material #1
TAN CLAY			34	45	11. Static water level: _____ mo./day/yr. 45 1/2 ft. below land surface Date 5-19-77
SAND & ROCK VERY			45	65	12. Pumping level below land surfaces: 46 ft. after 4 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100+ g.p.m.
LITTLE CLAY					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
BLACK SHALE			65	70	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.
					16. Nearest source of possible contamination: OLD ft. 160 Direction SE Type WELL Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name REDA Model number 1209P17HP 34 Volts 220 Length of drop pipe 63 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Waterhouse DRILL Business name _____ License No. _____ Address HANSTON KANS 223 Signed Dean Waterhouse Date 14 July 77 Authorized representative
18. Elevation:	19. Remarks: OWNER WILL POUR SLAB AROUND WELL AFTER PIPES ARE LAID & GROUP SETTLES				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 18 R 24 S 28 NE NE NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5