

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

TSAA

Laird

1. Location of well:		County NESS	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 36	Township number T 18 S R 25 E/W	Range number 25
2. Distance and direction from nearest town or city:		1/2 MILE WEST FROM LAIRD		Name of well: LLOYD SPRUILL		
Street address of well location if in city:		LAIRD		R.R. or street: City, state, zip code: GREAT DEND, KANSAS 67530		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 11/3/78 Well depth 28 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
BROWN CLAY		0 6		9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 18 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. SCH 40		
WHITE ROCK AND YELLOW CLAY		6 12		10. Screen: Manufacturer's name _____ JET STREAM Type PVC Dia. 5" Slot gage 1/16 Length 10' Set between 18 ft. and 28 ft. _____ ft. and _____ ft.		
LIGHT COLORED CLAY TURNING BLUE		12 17		Gravel pack? YES Size range of material #1		
FINE SILTY SAND AND WHITE ROCK (SOME CLAY)		17 25		11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 10/31/78		
BLUE SHALE		25 30		12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
				16. Nearest source of possible contamination: ft. 80 Direction NORTH Type DAM Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe 21 ft. capacity 2 1/2 g.p.m. Type: WINDMILL AND 2 1/2 CYLINDER <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		SHALLOW WELLS HARD TO COME BY IN THIS PART OF THE COUNTRY. SHALE IS HIGH EVEN ON HILLS. 2390 25 2365		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRILLING 243 Business name _____ License No. _____ Address HUNSTON, KANSAS Signed Dean Waterhouse Date 11/28/78 Authorized representative		

T 18 S R 25 E Sec 36 NE 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5