

USE TYPEWRITER  
POINT PEN-  
PRINT CLEAR

DIGHTON

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: In Dighton, Kansas		Fraction SE 1/4 SE 1/4 SW 1/4	Section number 18	Township number T 18 S	Range number R 28 E
2. Distance and direction from nearest city: Street address of well:		3. Owner of well: Lane Co. Implement R.R. or street: City, state, zip code: Dighton, KS 67839			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: X well 300' Sewer Line		6. Bore hole dia. 9 in. Completion date 2-11-77 Well depth 86 ft.	
5. Type and color of material		From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay		27	27	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gyp		27	37	9. Casing: Material <u>Plas</u> Height: <u>above</u> or below Threading <u>Welded</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>66</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>66</u> ft. depth gage No. <u>.250</u>	
Clay 'sdy'		37	55	10. Screen: Manufacturer's name <u>Jess &amp; Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> Slot gauge <u>1/16</u> Length <u>20 ft.</u> Set between <u>66</u> ft. and <u>86</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8</u>	
Rock H yelf		55	59	11. Static water level: <u>64</u> ft. below land surface Date <u>2-11-77</u>	
Gyp		59	62	12. Pumping level below land surfaces: <u>NA</u> <u>NA</u> ft. after <u>NA</u> hrs. pumping <u>NA</u> g.p.m. <u>NA</u> ft. after <u>NA</u> hrs. pumping <u>NA</u> g.p.m. Estimated maximum yield <u>NA</u> g.p.m.	
Clay		62	75	13. Water sample submitted: <u>NA</u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>2-11-77</u>	
Sd coarse		75	81	14. Well head completion: <u>12</u> inches above grade <u>Pitless adapter</u>	
Clay yellow		81	85	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.	
Shale		85	86	16. Nearest source of possible contamination: <u>Sewer</u> ft. <u>300</u> Direction <u>South</u> Type <u>Line</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(Use a second sheet if needed)				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:	19. Remarks: 2764 (TOPO) Well not finished by us; don't know pumping level or well head completion.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> 232 Business name <u>Scott City</u> KS 67871 Address <u>_____</u> Signature <u>_____</u> Authorized representative <u>3-7-77</u>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5