

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>McPherson</u>	Township name <u>New Hattaway</u>	Fraction <u>NW 1/4 NE 1/4</u>	Section number <u>20</u>	Town number <u>T-18-S</u>	Range number <u>R. 3-W</u>
Distance and direction from nearest town or city:	<u>6 1/2 mi S of McPherson on old 81</u>			3 Owner of well:	<u>Jerry P. Rhein</u>	
Street address of well location if in city:	Address: <u>1456 Ranch Road McPherson Kansas</u>					
Locate with "X" in section below:	Sketch map:			4 Well depth: <u>77</u> ft. Date of completion <u>8-29-75</u>	Well diameter <u>5"</u> in.	
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial		
				<input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material <u>PVC</u> Height: above/below		
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in.		
				Diam. _____ Weight _____ lbs./ft. _____		
				<u>5</u> in. to <u>27</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				_____ in. to _____ ft. depth		
2	Type and color of material	From	To	8 Screen:		
	<u>Top Soil</u>	<u>0</u>	<u>4</u>	Manufacturer <u>Peterson Lead</u>		
	<u>Red Buff Clay</u>	<u>4</u>	<u>17</u>	Type <u>PVC</u> Dia. <u>5"</u>		
	<u>Buff Clay & lime rock</u>	<u>17</u>	<u>21</u>	Slot/gouze <u>1/32</u> Length <u>20'</u>		
	<u>Red Buff Clay</u>	<u>21</u>	<u>42</u>	Set between <u>57</u> ft. and <u>77</u> ft.		
	<u>Dark Clay</u>	<u>42</u>	<u>58</u>	Fittings: <u>1 1/2 - 1 1/4"</u>		
	<u>Very fine sand & loose</u>	<u>58</u>	<u>59</u>	Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____		
	<u>Buff Clay</u>	<u>59</u>	<u>64</u>	9 Static water level: <u>17</u> ft. below land surface Date <u>8-29-75</u>		
	<u>fine sand - loose</u>	<u>64</u>	<u>65</u>	10 Pumping level below land surfaces: <u>39</u> ft. after <u>1 1/2</u> hrs. pumping <u>15</u> g.p.m.		
	<u>Dark Clay</u>	<u>65</u>	<u>70</u>	<u>39</u> ft. after _____ hrs. pumping _____ g.p.m.		
	<u>Lite sand - med. - sandstone</u>	<u>70</u>	<u>77</u>	Estimated maximum yield <u>30</u> g.p.m.		
	<u>Crack gravel</u>	<u>"</u>		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
	<u>Red & Green shales</u>	<u>77</u>	<u>80</u>	12 Well head completion: <u>12"</u>		
				<input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				<input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____		
				Depth: From <u>0</u> ft. to <u>16</u> ft.		
				14 Nearest source of possible contamination: _____		
				ft. <u>S.E</u> Direction <u>1000'</u> Type <u>Septic</u>		
				Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name _____		
				Model number _____ HP _____ Volts _____		
				Length of drop pipe _____ ft. capacity _____ g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation	The new home will be 1000 ft to 1500 ft S.E. on hill from well.					
Topography:						
<input checked="" type="checkbox"/> Hill						
<input type="checkbox"/> Slope						
<input type="checkbox"/> Upland						
<input type="checkbox"/> Valley						
	17 Water well contractor's certification:					
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.					
	<u>Peterson Bros INC</u> License No. <u>138</u>					
	Business name _____					
	Address <u>Box 150, Hindsboro, Kan</u>					
	Signed <u>Wallace Peterson</u> Date <u>8/29/75</u>					
	Authorized representative <u>By J.P.</u>					

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5