

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.


GRIGSTON

1831 W 27 A T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

ABC

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Scott	Township name Keystone	Fraction SW-NW-NE <sup>1</sup> <sub>4</sub>	Section number 27	Town number 18	Range number 31
Distance and direction from nearest town or city: Grigston, 3/8 mi west, 1/4 mi south Street address of well location if in city:				3 Owner of well: Raymond Schmidt Address: 803 Ora, Scott City, Ks. 67871		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map: 300 ft. east of center of west side		4 Well depth: 118' ft. Date of completion 5-20-75 Well diameter 26 in.
2 Type and color of material				From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay				0	40	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
Sand, gyp				40	60	7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 Weight 1.79 lbs./ft. 16 in. to 118 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth!
Sand, broken rock (loose)				60	800	8 Screen: Manufacturer W A Brown Enterprises Type Free Flo Dia. 16" Slot/gauze 1/8 Length 2" Set between 78 ft. and 118 ft. Fittings: 1/4x5/8 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
Sand, yellow clay, blue clay on bottom				100	120	9 Static water level: 78 ft. below land surface Date 5-20-75
BROCK 110						10 Pumping level below land surfaces: 113 ft. after 5 hrs. pumping 300 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 300 g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 4 inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.
						14 Nearest source of possible contamination: NA ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Worthington Model number 10H-61 HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation 2931 (TOPO) Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland Level <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply, Inc 136 Business name License No. Address 102 N 3rd, Garden City, Ks Signed [Signature] Date 6-19-75 Authorized representative		