

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 NE 1/4 NW 1/4	Section number 16	Township number T 18 S R	Range number 32 E
2. Distance and direction from nearest town or city: 1N, 2 1/2 E Street address of well location if in city: of Scott City, KS				3. Owner of well: C. A. Steele & Sons R.R. or street: 713 Main City, state, zip code: Scott City, KS 67871		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 145 ft. 7-2-75		
				7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
Clay		0	20	9. Casing: Material Steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.67 lbs./ft. Dia. 16 in. to 145 ft. depth; Wall Thickness: inches or Dia. ___ in. to ___ ft. depth; gage No. 188		
Gyp		20	37	10. Screen: Manufacturer's name Free Flow & Johnson Type Prime & Galve Steel dia. 16 in. <input checked="" type="checkbox"/> Slot gauze 125 x 100 Length 40 ft. Set between 105 ft. and 145 ft. ___ ft. and ___ ft. Gravel pack? yes Size range of material 3/4 - 1/2		
Fine sd T		37	50	11. Static water level: _____ mo./day/yr. 96 ft. below land surface Date 5-7-75		
Sd rock H		50	55	12. Pumping level below land surfaces: 119 ft. after 4 hrs. pumping 350 g.p.m. 127 ft. after 4 hrs. pumping 410 g.p.m. Estimated maximum yield 410 g.p.m.		
Fine sd clay		55	65	13. Water sample submitted: _____ mo./day/yr. Yes ___ No <input checked="" type="checkbox"/> Date _____		
Sd rock		65	95	14. Well head completion: ___ Pitless adapter ___ Inches above grade		
Fine sd clay		95	103	<input checked="" type="checkbox"/> Well grouted? ___ With: <input checked="" type="checkbox"/> Neat cement ___ Bentonite ___ Concrete Depth: From 0 ft. to 10 ft.		
Fine sd		103	116	16. Nearest source of possible contamination: ft. 2640 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No		
Sd coarse		116	129	17. Pump: Western Not installed Manufacturer's name Wells Land Roller Model number CS HP 20 Volts 480 Length of drop pipe 135 ft. capacity 410 g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
Fine sd clay T		129	139			
Yellow		139	160			
Shale		160				
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed _____ Date 7-20-76 Authorized representative		
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5