

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.


TRACTOR

18 3 2 W 1 7 D
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

DAD

1 Location of well:	County Scott	Township name Scott SE-NE SE	Fraction	Section number 17	Town number 18	Range number 32
Distance and direction from nearest town or city: 2E, 1/4 N of			3 Owner of well: Wesley Pitman			
Street address of well location if in city: Scott City, KS			Address: Scott City, KS 67871			
Locate with "X" in section below: 			Sketch map:			4 Well depth: 150 ft. Date of completion 8-8-75 Well diameter 9 in.
			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
			7 Casing: Material Plas Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. _____ Weight 1.8 lbs./ft. 5 in. to 110 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth			
2	Type and color of material	From	To	8 Screen: Manufacturer Jess & Lowell Type Plastic Dia. 5 Slot/gauze _____ Length _____ Set between 110 ft. and 150 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #1		
	Clay	0	9	9 Static water level: 88 ft. below land surface Date 8-8-75		
	Gyp	9	29	10 Pumping level below land surfaces: 98 ft. after 1 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
	Sd rock	29	34	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
	Fine sd clay	34	41	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
	Sd rock	41	65	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite _____ Depth: From 0 ft. to 15 ft.		
	Sdy clay	65	70	14 Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
	Fine sd clay	70	77	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Red Jacket Model number 75N1 HP 3/4 Volts 230 Length of drop pipe 150 ft. capacity 10 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
	Sd rock	77	80	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 9-11-75 Authorized representative		
	Fine sd clay	80	86			
	Sd rock	86	91			
	Fine sd clay	91	120			
	Fine sd clay T	120	131			
	Fine sd clay	131	135			
	Fine sd clay	135	137			
	Sd rock	137	144			
	Fine sd clay (use a second sheet if needed)	144	148			
16 Remarks: elevation	Yellow	148	158			
	Shale	158	160			
Topography:	BROCK 148'					
<input type="checkbox"/> Hill	2967 (TOPO)					
<input type="checkbox"/> Slope						
<input checked="" type="checkbox"/> Upland						
<input type="checkbox"/> Valley						