

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

SCOTT CITY

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABB

1. Location of well:		County Scott	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 17	Township number T 18 S R 32	Range number 32
2. Distance and direction from nearest town or city: Scott City Street address of well location if in city: one Mile North; 1 1/2 mile East			3. Owner of well: H. R. Burnett R.R. or street: RFD 3 City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 in. Completion date _____ Well depth 176 ft. 1-30-77		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Dirt and soil		0	20	9. Casing: Material PVC Height: Above ground _____ Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.265		
Gyp (caliche)		20	65	10. Screen: Manufacturer's name Jess & Lowell Type PVC Dia. 5" Slot/gauze 1/8" Length 20 ft Set between _____ ft. and 157 & 176 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes <input type="checkbox"/> no Size range of material 1/4" down		
Sand and gyp streaks		65	102	11. Static water level: _____ mo./day/yr. 125 ft. below land surface Date 1-15-77		
Sand and clay		102	141	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 + g.p.m.		
Hard gyp streak (rock-like)		141	148	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sand, fine to medium		148	176	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade		
Yellow clay		176	178	15. Well grouted? <input checked="" type="checkbox"/> yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
BROCK 176				16. Nearest source of possible contamination: ft. 30 Direction West Type Feedyard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)				17. Pump: _____ Not installed Manufacturer's name Aermotor Model number SE 50 HP 5 Volts 230 Length of drop pipe 161 ft. capacity 50 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
18. Elevation:	19. Remarks: 2972 (TOPO)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ABC Drilling, Inc. 246 Business name License No. _____ Address Scott City, KS 67871 Signed Sylvia H. Russ Date 5/23/77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

18 3 20 17 NW NE SE
T
R
Sec
1/4 1/4 1/4