

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

SCOTT CITY

1832W18 DBB

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DBB

1. Location of well:		County Scott	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 18	Township number T 18 S R 32	Range number 32
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
			1/2 N, 1/2 E of Scott City, KS Eva Young 505 College Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>10-27-75</u> Well depth <u>196</u> ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	35	9. Casing: Material <u>Plas.</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>Glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>176</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gauge No. <u>.250</u>		
Sd med		35	44	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5</u> in. <u>Slo</u> gauze <u>1/16</u> Length <u>20</u> ft. Set between <u>176</u> ft. and <u>196</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2-1/8</u>		
Clay		44	96	11. Static water level: <u>95</u> ft. below land surface Date <u>10-27-75</u> mo./day/yr.		
Sd rock		96	101	12. Pumping level below land surfaces: <u>105</u> ft. after <u>1</u> hrs. pumping <u>12</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>12</u> g.p.m.		
Sd coarse		101	107	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>		
Fine sd clay		107	120	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u> </u> inches above grade		
Clay		120	132	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
Sd rock		132	140	16. Nearest source of possible contamination: ft. <u>400</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse		140	152	17. Pump: Not installed Manufacturer's name <u>Aermator</u> Model number <u> </u> HP <u>3/4</u> Volts <u>230</u> Length of drop pipe <u>164</u> ft. capacity <u>12</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd rock		160	166	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address <u>Scott City, KS 67871</u> Signature <u>[Signature]</u> Date <u>11-20-75</u> Authorized representative		
Sd coarse		166	169			
Sd rock		169	174			
Sd coarse		174	195			
Clay		195	196			
Sd rock H (Use a second sheet if needed)		196	207			
18. Elevation:		19. Remarks:				
		Clay sdy 6lay 208 212				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		BROCK 212' 2965 (TOPO)				

1832W18
 DBB
 Sec 18
 R 32
 T 18
 S 18
 NW 1/4 SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5