

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 32	Township number T 18 S R 32 E/W	Range number 32		
2. Distance and direction from nearest town or city: 3S, 1E of Street address of well location if in city: Scott City, KS			3. Owner of well: Jerald Doornbos R.R. or street: 1020 Russell City, state, zip code: Scott City, KS 67871					
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 1 1/2 mi. Feed Lot ← X well		6. Bore hole dia. 26 in. Completion date _____ Well depth 146 ft. 7-13-76				
5. Type and color of material		From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
		Clay		0		21		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
		Sd coarse		21		32		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 146 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 188
		Clay		32		39		10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 16 in. <input checked="" type="checkbox"/> Gauze 125 Length 40 ft. Set between 106 ft. and 146 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/4-1/2
		Fine sd clay		39		78		11. Static water level: _____ mo./day/yr. 44 ft. below land surface Date 6-3-76
		Clay		78		82		12. Pumping level below land surfaces: 109 ft. after 4 hrs. pumping 750 g.p.m. 111 ft. after 4 hrs. pumping 760 g.p.m. Estimated maximum yield 760 g.p.m.
		Fine sd clay		82		96		13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		Clay		96		115		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade <input checked="" type="checkbox"/> Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
		Clay		115		125		16. Nearest source of possible contamination: Feed ft. 7920 Direction W Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		Clay		125		137		17. Pump: _____ Not installed Manufacturer's name Simmons Model number _____ HP _____ Volts _____ Length of drop pipe 135 ft. capacity 760 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Rock		137		142		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Scott City, KS 67871 Signed [Signature] Date 7-21-76 Authorized representative		
Clay		142		152				
18. Elevation:		19. Remarks:		(Use a second sheet if needed)				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley								

T
B
W
R
W
S
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5