

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SE 1/4 NE 1/4 NE 1/4	Section number 24	Township number T 18 S R 33 E 10	Range number
2. Distance and direction from nearest town or city: In Scott City, KS			3. Owner of well: Claude Hughes			
Street address of well location if in city:			R.R. or street: 912 Court			
			City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date _____ Well depth 200 ft. 6-29-76		
		<p>1 Mile</p> <p>1 Mile</p>		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	55	9. Casing: Material Plas. Height: Above or below Threaded _____ Welded Clue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight 1.8 lbs./ft. Dia. 5 in. to 180 ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. 250		
Sdy clay		55	85	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5 in. Slot/gauge 1/16 Length 20 ft. Set between 180 ft. and 200 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 4-1/8		
Sd coarse		75	84	11. Static water level: _____ mo./day/yr. 105 ft. below land surface Date 6-22-76		
Clay		84	95	12. Pumping level below land surfaces: 115 ft. after 1 hrs. pumping 50 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.		
Fine sd clay		95	117	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Fine sd T		117	125	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Gyp		125	130	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 15 ft.		
Clay		130	134	16. Nearest source of possible contamination: Sewer ft. 20 Direction W Type Line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No		
Sd coarse		134	140	17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 500T1 HP 5 Volts 220 Length of drop pipe 174 ft. capacity 50 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
Fine sd clay		140	146	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address: Scott City, KS 67871 Signed: _____ Date 7-22-76 Authorized Representative		
Sd med		146	150			
Sd T		150	158			
Sd rock		158	161			
Sd coarse		161	170			
Sd rock H		170	177			
Sd coarse	(Use a second sheet if needed)	177	179			
18. Elevation:	19. Remarks:	Sd rock H	179	185		
		Clay	185	197		
		Sd coarse	197	198		
		Clay	198	207		
		Yellow	207	215		
		Shale	215			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 18 S R 33 E 10

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5