

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Scott	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 16	Township number T 18 S R 34	Range number 34
2. Distance and direction from nearest town or city: 8W, 1N, 2W of Street address of well location if in city: Scott City, KS			3. Owner of well: Lottie McGhee R.R. or street: % Don Christy City, state, zip code: Scott City, KS 67871		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: <i>X well 1/2 mi.</i> <i>Septic</i>		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date _____ Well depth 152 ft. 9-19-75
Clay			00	22	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Fine sd clay			22	35	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sd coarse			35	57	9. Casing: Material Steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 152 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. .188
Sd rock H			57	63	10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 16 in. <input checked="" type="checkbox"/> gauze .125 Length 30 ft. Set between 122 ft. and 152 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4-1/4 ft.
Fine sd clay			63	105	11. Static water level: _____ mo./day/yr. 125 ft. below land surface Date 9-5-75
Sd coarse			105	124	12. Pumping level below land surfaces: 125 ft. after 4 hrs. pumping 440 g.p.m. 135 ft. after 4 hrs. pumping 500 g.p.m. Estimated maximum yield 500 g.p.m.
Yellow			124	141	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Shale			141	152	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 2640 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number GE HP 25 Volts 460 Length of drop pipe 140 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <i>Septic</i>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed <i>[Signature]</i> Date 7-20-76 Authorized representative		

T
8
W
F
3
T
6
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5