

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Wichita	Township name Leoti	Fraction NW 1/4	Section number 34	Town number 18	Range number 35
Distance and direction from nearest town or city: .25 S 1.5 E 2 S				3 Owner of well: Joe Berning Jr.		
Street address of well location if in city: .3 E .25 S of Marienthal, Ks				Address: Marienthal, Kansas		
Locate with "X" in section below:			Sketch map:			4 Well depth: 145 ft. Date of completion 2-23-76 Well diameter 12 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dig <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Soil			0	10	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
clay			10	52	7 Casing: Material Steel Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. _____ Weight 134 lbs./ft. _____ 12 in. to 125 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth	
Sandy clay			52	70	8 Screen: Manufacturer W.A. Brown Type STEEL Dia. 12 Slot/gauze _____ Length 20' Set between 125 ft. and 145 ft. _____ Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8 - 5/8	
clay			70	91	9 Static water level: 115 ft. below land surface Date 2-20-76	
Sandy clay			91	122	10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 125 g.p.m.	
clay			122	128	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sand			128	134	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
clay			134	135	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.	
Good clean sand			135	143	14 Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
yellow			143	145	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Valley Model number 23611 HP 15 Volts 440 Length of drop pipe 135 ft. capacity 125 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Blue Shale.			145		16 Remarks: elevation	
(use a second sheet if needed)					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. WILMERY DRILLING 256 Business name License No. Address 405 Antelope Scott City, Ks. Signed John Wilmer Date 2-27-80 Authorized representative	

18 35 W 34 NW

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5